FLUSH WITH
GROUND
ELELVATION

COVER

NOTE: IN PAVEMENT OR TRAFFIC AREAS
VALVE BOX AND COVER SHALL BE TRAFFIC
TYPE. SEE MATERIAL SPECIFICATIONS IN
CONTRACT DOCUMENTS.

VALVE BOX

6" PLUG OR CAP
ARRANGEMENT

BOX SHALL BE MINIMUM
16"x10-3/4"x12" AND 6"
EXTENSIONS. MADE OF
INJECTION MOLDED PLASTIC
MANUFACTURED BY BROOMS
PRODUCTS, INC. OR
APPROVED EQUAL

GRANULAR MATERIAL
4" MINIMUM DEPTH

EXISTING SEWER SERVICE

CONNECT TO EXISTING SERVICE
WITH FERNCO COUPLING

SANITARY TEE

NOTE: LONG SWEEP WYE
IS ALSO ACCEPTABLE

TYPICAL CLEANOUT ASSEMBLY

NOT TO SCALE

HENDERSONVILLE UTILITY DISTRICT | STANDARD DETAIL | S-5