

## **FINAL FIRE INSPECTION**

### Address Numbers

- Visible and Legible

### Knox-Box

- Verify proper building access - Key, Fob etc.
- Keys for Knox-Box

### Fire Sprinkler System

- All system operations functioning
- FDC Access & Condition

### Commercial Cooking Hood Suppression System

- Cleaned and Serviced Bi-Annually

### Exit Signs

- Verify Illumination and Test Batteries

### Emergency Lights

- Test Functionality

### Extinguishers

- Verify Size & Service Date

### Electrical Conditions

- Panel Clearance
- Ext. Cords
- Multiplug Adapters
- Open Junction Boxes
- Means of Egress
- Clear of Obstructions

### Doors

- Hardware
- Swing & Operation

### Storage

- Electrical / Mechanical Rooms
- Under Stairs
- Flammable and Hazardous Materials

### Smoke Detectors (Independent of Alarm System)

- Test Functionality

### Fire Alarm System

- Inspect & Test Annually & Deficiencies Corrected